

**METROPOLITAN UTILITIES DISTRICT OF OMAHA  
REPORT OF WATER ANALYSIS**

Florence Plant

Monthly Averages

Source: Finished Water

Date: September 2017

Temperature	<u>23.2</u>	°C
Turbidity (NTU)	<u>0.09</u>	Units
Suspended Solids	<u>-</u>	mg/L
Color	<u>2</u>	Units
Dissolved Oxygen (O <sub>2</sub> )	<u>8.9</u>	mg/L
Langelier Index	<u>0.89</u>	
UV-ABS @ 254 nm	<u>4.0</u>	ABS/m
Total Organic Carbon	<u>3.2</u>	mg/L
Specific Conductance @ 25 °C	<u>760</u>	µmhos
Dissolved Solids (Calculated)	<u>504</u>	mg/L
Silica (SiO <sub>2</sub> )	<u>6.4</u>	mg/L
pH	<u>8.87</u>	Units
Alkalinity (CaCO <sub>3</sub> )		
Phenolphthalein (P)	<u>6</u>	mg/L
Total (M)	<u>70</u>	mg/L
Total Hardness (CaCO <sub>3</sub> )	<u>167</u>	mg/L
Carbonate	<u>70</u>	mg/L
Non-carbonate	<u>97</u>	mg/L
Nitrogen (N)		
Ammonia	<u>0.18</u>	mg/L
Nitrite	<u>-</u>	mg/L
Nitrate	<u>0.36</u>	mg/L
Chlorine (Cl <sub>2</sub> )		
Free Residual	<u>-</u>	mg/L
Total Residual	<u>2.42</u>	mg/L
Surfactants (MBAS)	<u>-</u>	mg/L
Radioactivity :		
Gross Alpha (α)	<u>0.2</u>	pCi/L
Beta Emitters (β)	<u>4.3</u>	pCi/L
Radium 226+228	<u>-</u>	pCi/L
Uranium	<u>-</u>	mg/L

Cations :			
Calcium	(Ca)	<u>39</u>	mg/L
Magnesium	(Mg)	<u>17</u>	mg/L
Sodium	(Na)	<u>89</u>	mg/L
Potassium	(K)	<u>6</u>	mg/L
Anions :			
Bicarbonate	(HCO <sub>3</sub> )	<u>71</u>	mg/L
Carbonate	(CO <sub>3</sub> )	<u>7</u>	mg/L
Hydroxide	(OH)	<u>0.11</u>	mg/L
Fluoride	(F)	<u>0.90</u>	mg/L
Chloride	(Cl)	<u>19</u>	mg/L
Bromide	(Br)	<u>-</u>	mg/L
Nitrite	(NO <sub>2</sub> )	<u>-</u>	mg/L
Nitrate	(NO <sub>3</sub> )	<u>1.59</u>	mg/L
Phosphate-ortho	(PO <sub>4</sub> )	<u>&lt;0.05</u>	mg/L
			mg/L
Sulfate	(SO <sub>4</sub> )	<u>246</u>	mg/L
Trace Inorganics :			
Aluminum	(Al)	<u>0.44</u>	mg/L
Copper	(Cu)	<u>&lt; 0.01</u>	mg/L
Iron	(Fe)	<u>&lt;0.02</u>	mg/L
Lithium	(Li)	<u>0.05426</u>	mg/L
Manganese	(Mn)	<u>&lt; 0.01</u>	mg/L
Strontium	(Sr)	<u>0.4414</u>	mg/L
Zinc	(Zn)	<u>&lt; 0.01</u>	mg/L
Antimony	(Sb)	<u>&lt; 1.0</u>	µg/L
Arsenic	(As)	<u>&lt; 1.0</u>	µg/L
Barium	(Ba)	<u>31.04</u>	µg/L
Beryllium	(Be)	<u>&lt; 1.0</u>	µg/L
Cadmium	(Cd)	<u>&lt; 1.0</u>	µg/L
Chromium	(Cr)	<u>1.43</u>	µg/L
Lead	(Pb)	<u>&lt; 1.0</u>	µg/L
Mercury	(Hg)	<u>-</u>	µg/L
Nickel	(Ni)	<u>&lt; 1.0</u>	µg/L
Selenium	(Se)	<u>&lt; 5.0</u>	µg/L
Thallium	(Tl)	<u>&lt; 1.0</u>	µg/L

Bacteriological Quality : Distribution System

---

Meets USEPA drinking water standards:

---

T. coli: 0.34%      E. coli: absent

---

Cryptosporidium: N.D.      Giardia: N.D.

---

Organics :

Atrazine	<u>-</u>	µg/L
Metolachlor	<u>-</u>	µg/L

M. Feltes  
Chemist

N. D. = Not Detected