

**METROPOLITAN UTILITIES DISTRICT OF OMAHA  
REPORT OF WATER ANALYSIS**

Platte West Plant

Monthly Averages

Source: Finished Water

Date: February 2018

Temperature	15.1	° C
Turbidity (NTU)	0.07	Units
Total Organic Carbon	1.7	mg/L
Color	2	Units
Dissolved Oxygen (O <sub>2</sub> )	4.6	mg/L
Langelier Index	0.94	
UV-ABS @ 254 nm	6.9	ABS/m
Specific Conductance @ 25 °C	481	µmhos
Dissolved Solids (Calculated)	299	mg/L
Silica (SiO <sub>2</sub> )		mg/L
pH	8.66	mg/L
Alkalinity (CaCO <sub>3</sub> )		
Phenolphthalein (P)	8	mg/L
Total (M)	123	mg/L
Total Hardness (CaCO <sub>3</sub> )	159	mg/L
Carbonate	123	mg/L
Non-carbonate	36	mg/L
Nitrogen (N)		
Ammonia	0.02	mg/L
Nitrite	-	mg/L
Nitrate	0.57	mg/L
Chlorine (Cl <sub>2</sub> )		
Free Residual	0.00	mg/L
Total Residual	2.30	mg/L
Surfactants (MBAS)	-	mg/L
Trace Inorganics:		
Iron (total)	<0.02	mg/L
Iron (dissolved)	-	mg/L
Manganese (total)	0.016	mg/L
Manganese (dissolved)	-	mg/L
	-	mg/L

Cations :

Calcium	(Ca)	33	mg/L
Magnesium	(Mg)	10	mg/L
Sodium	(Na)	-	mg/L
Potassium	(K)	-	mg/L

Anions :

Bicarbonate	(HCO <sub>3</sub> )	131	mg/L
Carbonate	(CO <sub>3</sub> )	9.6	mg/L
Hydroxide	(OH)	-	mg/L
Fluoride	(F)	0.77	mg/L
Chloride	(Cl)	21	mg/L
Bromide	(Br)	-	mg/L
Nitrite	(NO <sub>2</sub> )	-	mg/L
Nitrate	(NO <sub>3</sub> )	2.53	mg/L
Phosphate-ortho	(PO <sub>4</sub> )	0.12	mg/L
			mg/L
Sulfate	(SO <sub>4</sub> )	92	mg/L

Trace Inorganics :

Aluminum	(Al)	-	mg/L
Copper	(Cu)	-	mg/L
Iron	(Fe)	< 0.02	mg/L
Lithium	(Li)	-	mg/L
Manganese	(Mn)	0.016	mg/L
Strontium	(Sr)	-	mg/L
Zinc	(Zn)	-	mg/L
Antimony	(Sb)	-	µg/L
Arsenic	(As)	-	µg/L
Barium	(Ba)	-	µg/L
Beryllium	(Be)	-	µg/L
Cadmium	(Cd)	-	µg/L
Chromium	(Cr)	-	µg/L
Lead	(Pb)	-	µg/L
Mercury	(Hg)	-	µg/L
Nickel	(Ni)	-	µg/L
Selenium	(Se)	-	µg/L
Thallium	(Tl)	-	µg/L

Bacteriological Quality : Distribution System

Meets U.S.E.P.A. drinking water standards:

T. Coli - 0.00%; E. Coli - Absent

Giardia - N.D. Cryptosporidium - N.D.

Organics :

Atrazine	_____	µg/L
Metolachlor	_____	µg/L

*Jessica Martin*  
Water Analyst