



METROPOLITAN

UTILITIES DISTRICT

Water Application Guidelines

M.U.D. Water Rules and Regulations (www.mudomaha.com) require that a master plumber complete all work on a water service. Below is a list of information required for water service application. If this information is not provided accurately or in entirety, it may result in delay of processing the water service application:

1. **Project Information**
Include project name, type of business, type of water service (single-family, multi-family, commercial), builder's name, and property owner.
2. **Address**
Provide the correct address of the property. For example, *18001 W. Dodge Road*. Avoid using general address locations such as 180th & Dodge.
3. **Legal Description**
Provide the correct legal description of the property. For example, *Lot 3, Blk 10, Keystone Addition*. Please include a copy of a surveyor's certificate for lands descriptions.
4. **Plumbing Company**
Provide the name of the plumbing company for the licensed master plumber.
5. **Tap Size**
 - A minimum 1-inch tap is required for all new construction projects.
 - A 3/4-inch tap shall only be allowed on reconnects of existing water services.
 - A pre-tap inspection is required when an existing water service is moved or altered.
 - For large taps, provide the tap & service size in order for M.U.D. to determine the price.
 - Large services will require approval of the M.U.D. engineering department.
6. **Meter Location and Size**
 - All meters will be set inside the structure unless pre-approved by the M.U.D. engineering department for a meter pit.
 - A minimum 3/4-inch meter is required for all new homes.
 - Meter sizes 1-inch and larger require a demand sheet and approval from the M.U.D. engineering department.

Please refer to the Billing Price Book (www.mudomaha.com) for the most current fees.

If you have questions regarding these guidelines, please contact M.U.D. at one of the following phone numbers:

1. Builder & Contractor Services: 402-504-7014
2. Engineering Department: 402-504-7920

Revised 04/07/2014