

**METROPOLITAN UTILITIES DISTRICT OF OMAHA
REPORT OF WATER ANALYSIS**

Platte West Plant

Monthly Averages

Source: Finished Water

Date: January 2019

Temperature	15.3	° C
Turbidity (NTU)	0.08	Units
Total Organic Carbon	2.0	mg/L
Color	2	Units
Dissolved Oxygen (O ₂)	2.2	mg/L
Langelier Index	1.01	
UV-ABS @ 254 nm	3.8	ABS/m
Specific Conductance @ 25 °C	449	µmhos
Dissolved Solids (Calculated)	220	mg/L
Silica (SiO ₂)	22.1	mg/L
pH	8.84	
Alkalinity (CaCO ₃)		
Phenolphthalein (P)	13	mg/L
Total (M)	99	mg/L
Total Hardness (CaCO ₃)	150	mg/L
Carbonate	114	mg/L
Non-carbonate	36	mg/L
Nitrogen (N)		
Ammonia	0.06	mg/L
Nitrite	-	mg/L
Nitrate	-	mg/L
Chlorine (Cl ₂)		
Free Residual	0.00	mg/L
Total Residual	2.12	mg/L
Surfactants (MBAS)	-	mg/L
Trace Inorganics:		
Iron (total)	<0.02	mg/L
Iron (dissolved)	-	mg/L
Manganese (total)	0.02	mg/L
Manganese (dissolved)	-	mg/L
	-	mg/L

Cations :			
Calcium	(Ca)	46	mg/L
Magnesium	(Mg)	9	mg/L
Sodium	(Na)	29	mg/L
Potassium	(K)	9	mg/L

Anions :			
Bicarbonate	(HCO ₃)	89	mg/L
Carbonate	(CO ₃)	16	mg/L
Hydroxide	(OH)	-	mg/L
Fluoride	(F)	0.67	mg/L
Chloride	(Cl)	-	mg/L
Bromide	(Br)	-	mg/L
Nitrite	(NO ₂)	-	mg/L
Nitrate	(NO ₃)	-	mg/L
Phosphate-ortho	(PO ₄)	-	mg/L
			mg/L
Sulfate	(SO ₄)	-	mg/L

Trace Inorganics :			
Aluminum	(Al)	<0.01	mg/L
Copper	(Cu)	<0.01	mg/L
Iron	(Fe)	<0.02	mg/L
Lithium	(Li)	0.02	mg/L
Manganese	(Mn)	0.02	mg/L
Strontium	(Sr)	0.25	mg/L
Zinc	(Zn)	<0.01	mg/L

Antimony	(Sb)	<1.0	µg/L
Arsenic	(As)	2.59	µg/L
Barium	(Ba)	63.5	µg/L
Beryllium	(Be)	<1.0	µg/L
Cadmium	(Cd)	<1.0	µg/L
Chromium	(Cr)	1.67	µg/L
Lead	(Pb)	<1.0	µg/L
Mercury	(Hg)	-	µg/L
Nickel	(Ni)	<1.0	µg/L
Selenium	(Se)	<5.0	µg/L
Thallium	(Tl)	<1.0	µg/L

Bacteriological Quality : Distribution System

Meets U.S.E.P.A. drinking water standards:

TC - 0.00%; E. coli - Absent

Giardia - Cryptosporidium -

Organics :

Atrazine _____ µg/L

Metolachlor _____ µg/L

Raksha Chhetri
Water Analyst